
CERTIFICACIÓN DE PRODUCTO

Bases Portafusibles



Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50484998

Blatt *Sheet*
0001

| Ihr Zeichen <i>Client Reference</i> | Unser Zeichen <i>Our Reference</i> | Ausstellungsdatum <i>Date of Issue</i> |
|-------------------------------------|------------------------------------|--|
| Q.Y.M. | ZC10-YQ-14712314 006 | 11.11.2020 (day/mo/yr) |

Genehmigungsinhaber *License Holder*
MERSEN ZHEJIANG CO., LTD.
Building 2#,
No. 1228, Chenwang Road,
Technical Development Zone,
Changxing, Huzhou City,
313100 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*
MERSEN ZHEJIANG CO., LTD.
Building 2#,
No. 1228, Chenwang Road,
Technical Development Zone,
Changxing, Huzhou City,
313100 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111231595

Geprüft nach *Tested acc. to*

EN 60269-1:2007+A1+A2
EN 60269-6:2011

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Fuse Link (Low-voltage Fuse for PV System)

| | | |
|-------------------------------|---|---|
| Fuse-link Type Designation | : PV10 | 5 |
| Rated Voltage | : DC 1000V | |
| Rated Current | : 2A, 3A, 4A, 5A, 6A, 8A, 10A, 12A, 15A, 20A | |
| Rated Breaking Capacity: | 10kA | |
| Breaking Range | : gPV | |
| Rated Power Dissipation: | no more than 2.2W at 0.7In no more than 3.5W at In | |
| Size | : 10mm*38mm | |
| Arc Voltage Limits | : 3500V (Peak Value) | |

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li

C E R T I F I C A T E



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50485000 0001

Report No.: 14712314 006

Holder: MERSEN ZHEJIANG CO., LTD.
Building 2#,
No. 1228, Chenwang Road,
Technical Development Zone,
Changxing, Huzhou City,
313100 Zhejiang
P.R. China

Product: Fuse Link
(Low-voltage Fuse for PV System)

Identification: Type Designation: PV10
Serial No.: n.a.
Remark: Issued in conjunction with TÜV Rheinland
license R 50484998 0001.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 11.11.2020

James Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Ⓒ The CE marking may be used if all relevant and effective EC Directives are complied with. Ⓒ

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50561896

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Q.Y.M.

Unser Zeichen *Our Reference*
ZC10-YQ-CN22LTTG 001

Ausstellungsdatum *Date of Issue*
21.10.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
MERSEN ZHEJIANG CO., LTD.
Building 2#,
No. 1228, Chenwang Road,
Technical Development Zone,
Changxing, Huzhou City,
313100 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*
MERSEN ZHEJIANG CO., LTD.
Building 2#,
No. 1228, Chenwang Road,
Technical Development Zone,
Changxing, Huzhou City,
313100 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60269-1:2007+A1+A2
EN 60269-6:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

(Low-voltage Fuse)

| | | |
|-------------------------|----------------------|---|
| Type Designation | : PV10 | 5 |
| Rated Voltage | : DC 1000V | |
| Rated Current | : 25A, 30A, 35A, 40A | |
| Rated Breaking Capacity | : 5kA | |
| Breaking Range | : gPV | |
| Rated Power Dissipation | : 7.5W | |
| Size | : 10mmx38mm | |
| Arc Voltage Limits | : 3500V (Peak Value) | |

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifizierungsstelle



James Li